

**Water Quality Parameter Monitoring Form  
Oregon Health Authority  
Lead & Copper Rule Corrosion Control**

Day	PH	Alk	Phos	Other	Y/N
1	7.6				Y
2	7.2				Y
3	7.3				Y
4	7.3				Y
5	7.4				Y
6	7.6				Y
7	7.4				Y
8	7.2				Y
9	7.8				Y
10	7.1				Y
11	7.9				Y
12	7.8				Y
13	7.7				Y
14	7.5				Y
15	7.6				Y
16	7.3				Y
17	7.6				Y
18	7.3				Y
19	7.2				Y
20	7.1				Y
21	7.1				Y
22	7.3				Y
23	7.7				Y
24	7.6				Y
25	7.3				Y
26	7.8				Y
27	7.7				Y
28	7.6				Y
29	7.5				Y
30	7.9				Y
31	#N/A				Y
<b>Total N's</b> (No = N = Excursion)					<u>0</u>

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 4100254

System Name: City of Depoe Bay

Entry Point: A

Sample Period: Apr-23  
Month/Year

**Number of excursions during this month:** 0  
(Count the number of days when any WQP was less than the minimum required)


**Number of excursions during this month:** 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

For OHA use only

**Minimum Water Quality  
Parameter(s) as set by State:**

	MIN	
pH	7.1	
Alk		(Alkalinity)
PO4		(Orthpphosphate)
Other		( )

Print Name: Brady Weidner

Signature: 

Date: 5-8-23  
Sent to DWP within 10 days after end of sampling period.