

**Water Quality Parameter Monitoring Form
Oregon Health Authority
Lead & Copper Rule Corrosion Control**

Day	PH	Alk	Phos	Other	Y/N
1	7.2				Y
2	7.1				Y
3	7.1				Y
4	7.1				Y
5	7.1				Y
6	7.1				Y
7	7.2				Y
8	7.2				Y
9	7.4				Y
10	7.2				Y
11	7.2				Y
12	7.1				Y
13	7.1				Y
14	7.1				Y
15	7.1				Y
16	7.1				Y
17	7.1				Y
18	7.2				Y
19	7.1				Y
20	7.2				Y
21	7.1				Y
22	7.1				Y
23	7.1				Y
24	7.1				Y
25	7.1				Y
26	7.3				Y
27	7.1				Y
28	7.1				Y
29	7.1				Y
30	7.1				Y
31	7.1				Y
Total N's (No = N = Excursion)					0

<<Have minimums been met for this day?	ENTRY POINT	
	PWS ID:	4100254
	System Name:	City of Depoe Bay
	Entry Point:	A
Sample Period:	Jul-23	Month/Year

Number of excursions during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter(s) as set by State:	
	MIN
pH	7.1
Alk	
PO4	
Other	
	(Alkalinity) (Orthpphosphate) ()

Print Name: Brady Weidner
Signature: [Signature]
Date: 8-8-2023
Sent to DWP within 10 days after end of sampling period.