

**Water Quality Parameter Monitoring Form  
Oregon Health Authority  
Lead & Copper Rule Corrosion Control**

Day	PH	Alk	Phos	Other	Y/N
1	7.1				Y
2	7.4				Y
3	7.3				Y
4	7.4				Y
5	7.2				Y
6	7.3				Y
7	7.2				Y
8	7.1				Y
9	7.4				Y
10	7.2				Y
11	7.2				Y
12	7.1				Y
13	7.1				Y
14	7.1				Y
15	7.1				Y
16	7.1				Y
17	7.2				Y
18	7.3				Y
19	7.1				Y
20	7.4				Y
21	7.6				Y
22	7.5				Y
23	7.5				Y
24	7.1				Y
25	7.2				Y
26	7.4				Y
27	7.2				Y
28	7.3				Y
29	7.2				Y
30	7.2				Y
31	7.2				Y
<b>Total N's</b> (No = N = Excursion)					2

<<Have minimums been met for this day?	<b>ENTRY POINT</b>
PWS ID:	4100254
System Name:	City of Depoe Bay
Entry Point:	A
Sample Period:	Aug-23
	Month/Year


**Number of excursions during this month:** 2  
(Count the number of days when any WQP was less than the minimum required)

**Number of excursions during this month:** 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

For OHA use only

Minimum Water Quality Parameter(s) as set by State:	
	MIN
pH	7.1
Alk	
PO4	
Other	
	(Alkalinity) (Orthpphosphate) ( )

**Print Name:** Brady Weidner

**Signature:** 

**Date:** 9-8-2023

Sent to DWP within 10 days after end of sampling period.