

**Water Quality Parameter Monitoring Form  
Oregon Health Authority  
Lead & Copper Rule Corrosion Control**

Day	PH	Alk	Phos	Other	Y/N
1	7.6				Y
2	7.8				Y
3	7.3				Y
4	7.3				Y
5	7.3	40.0			Y
6	7.2				Y
7	7.1				Y
8	7.1				Y
9	7.1				Y
10	7.2				Y
11	7.2	40.0			Y
12	7.1				Y
13	7.5				Y
14	7.5				Y
15	7.6				Y
16	7.8				Y
17	7.6				Y
18	7.8	40.0			Y
19	7.8				Y
20	7.8				Y
21	7.8				Y
22	7.7				Y
23	7.8				Y
24	7.7				Y
25	7.7	40.0			Y
26	7.7				Y
27	7.7				Y
28	7.5				Y
29	7.3				Y
30	7.2				Y
31	7.3				Y
<b>Total N's</b> (No = N = Excursion)					<u>0</u>

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 4100254

System Name: City of Depoe Bay

Entry Point: A

Sample Period: Dec-23  
Month/Year

**Number of excursions during this month:** 0  
(Count the number of days when any WQP was less than the minimum required)

**Number of excursions during this month:** 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

For OHA use only

**Minimum Water Quality  
Parameter(s) as set by State:**

	MIN	
pH	7.1	
Alk	24	(Alkalinity)
PO4		(Orthpphosphate)
Other		( )

Print Name: Brady Weidner

Signature: [Signature]

Date: 1-5-24  
Sent to DWP within 10 days after end of sampling period.