

**Water Quality Parameter Monitoring Form
Oregon Health Authority
Lead & Copper Rule Corrosion Control**

Day	PH	Alk	Phos	Other	Y/N
1	7.5				Y
2	7.8	40.0			Y
3	7.6				Y
4	7.5				Y
5	7.5				Y
6	7.2				Y
7	7.1	40.0			Y
8	7.3				Y
9	7.2				Y
10	7.3				Y
11	7.3				Y
12	7.4				Y
13	7.5	40.0			Y
14	7.4				Y
15	7.6				Y
16	7.6				Y
17	7.5				Y
18	7.3				Y
19	7.3	40.0			Y
20	7.4				Y
21	7.2				Y
22	7.4				Y
23	7.7				Y
24	7.1				Y
25	7.1	40.0			Y
26	7.3				Y
27	7.4				Y
28	7.3				Y
29	7.2				Y
30					
31					

Total N's 8
(No = N = Excursion)

<<Have minimums been met for this day?		ENTRY POINT	
PWS ID:	4100254		
System Name:	City of Depoe Bay		
Entry Point:	A		
Sample Period:	Feb-24		
Month/Year	<u>Feb-2024</u>		

Number of excursions during this month: 8
(Count the number of days when any WQP was less than the minimum required)

Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter(s) as set by State:	
	MIN
pH	7.1
Alk	
PO4	
Other	

(Alkalinity)
(Orthpphosphate)
(_____)

Print Name: Brady Weidner

Signature:

Date: March 7 2024
Sent to DWP within 10 days after end of sampling period.