

**Water Quality Parameter Monitoring Form  
Oregon Health Authority  
Lead & Copper Rule Corrosion Control**

*DEC 2024*

Day	PH	Alk	Phos	Other	Y/N
1	7.2				Y
2	7.4	40.0			Y
3	7.6				Y
4	7.3				Y
5	7.2				Y
6	7.1				Y
7	7.2				Y
8	7.1				Y
9	7.5	40.0			Y
10	7.2				Y
11	7.2				Y
12	7.1				Y
13	7.3				Y
14	7.2				Y
15	7.2				Y
16	7.2	60.0			Y
17	7.6				Y
18	7.1				Y
19	7.4				Y
20	7.1				Y
21	7.6				Y
22	7.2				Y
23	7.4	60.0			Y
24	7.3				Y
25	7.3				Y
26	7.2				Y
27	7.2				Y
28	7.1				Y
29	7.3				Y
30	7.3	40.0			Y
31	7.3				Y
<b>Total N's</b> (No = N = Excursion)					<b>0</b>

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 4100254

System Name: City of Depoe Bay

Entry Point: A

Sample Period: Dec-24  
Month/Year

**Number of excursions during this month:** 0  
(Count the number of days when any WQP was less than the minimum required)

**Number of excursions during this month:** 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

For OHA use only

**Minimum Water Quality  
Parameter(s) as set by State:**

	MIN	
pH	7.1	
Alk	24	(Alkalinity)
PO4		(Orthpphosphate)
Other		(_____)

Print Name: Brady Weidner

Signature: *[Signature]*

Date: 1-3-25  
Sent to DWP within 10 days after end of sampling period.