

**Water Quality Parameter Monitoring Form
Oregon Health Authority
Lead & Copper Rule Corrosion Control**

JAN - 25

Day	PH	Alk	Phos	Other	Y/N
1	7.6				Y
2	7.5				Y
3	7.6				Y
4	7.4				Y
5	7.2				Y
6	7.1	60.0			Y
7	7.2				Y
8	7.4				Y
9	7.5				Y
10	7.4				Y
11	7.4				Y
12	7.2				Y
13	7.3	40.0			Y
14	7.3				Y
15	7.3				Y
16	7.2				Y
17	7.2				Y
18	7.2				Y
19	7.3				Y
20	7.2	40.0			Y
21	7.2				Y
22	7.1				Y
23	7.1				Y
24	7.1				Y
25	7.2				Y
26	7.1				Y
27	7.2	60.0			Y
28	7.3				Y
29	7.1				Y
30	7.2				Y
31	7.1				Y
Total N's (No = N = Excursion)					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100254

System Name: City of Depoe Bay

Entry Point: A

Sample Period: Jan-25
Month/Year

Number of excursions during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameter(s) as set by State:**

	MIN	
pH	7.1	
Alk	24	(Alkalinity)
PO4		(Orthpphosphate)
Other		()

Print Name: BRADY WEIDNER

Signature: *[Signature]*

Date: 2-3-25
Sent to DWP within 10 days after end of sampling period.