

**Water Quality Parameter Monitoring Form
Oregon Health Authority
Lead & Copper Rule Corrosion Control**

Day	PH	Alk	Phos	Other	Y/N
1	7.1				Y
2	7.1				Y
3	7.4	40.0			Y
4	7.2				Y
5	7.2				Y
6	7.3				Y
7	7.3				Y
8	7.3				Y
9	7.4				Y
10	7.4	40.0			Y
11	7.4				Y
12	7.4				Y
13	7.4				Y
14	7.5				Y
15	7.3				Y
16	7.2				Y
17	7.2	60.0			Y
18	7.1				Y
19	7.3				Y
20	7.2				Y
21	7.5				Y
22	7.3				Y
23	7.5				Y
24	7.1	40.0			Y
25	7.1				Y
26	7.4				Y
27	7.3				Y
28	7.2				Y
29					
30					
31					
Total N's (No = N = Excursion)					0

<<Have minimums been met for this day?	ENTRY POINT
PWS ID:	4100254
System Name:	City of Depoe Bay
Entry Point:	A
Sample Period:	Feb-25
	<i>Month/Year</i>


Number of excursions during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality	
Parameter(s) as set by State:	
	MIN
pH	7.1
Alk	24
PO4	
Other	
	(Alkalinity) (Orthpphosphate) ()

Print Name: BRADY WEIDNER

Signature: 

Date: 3-3-25
Sent to DWP within 10 days after end of sampling period.