



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
01	7.8	21	-	-	Y
02	7.9	21	-	-	Y
03	7.9	21	-	-	Y
04	7.9	20	-	-	Y
05	7.9	20	-	-	Y
06	7.9	19	-	-	Y
07	8.0	20	-	-	Y
08	8.0	20	-	-	Y
09	7.8	19	-	-	Y
10	7.9	20	-	-	Y
11	8.0	21	-	-	Y
12	8.0	21	-	-	Y
13	8.0	22	-	-	Y
14	7.9	20	-	-	Y
15	8.0	19	-	-	Y
16	7.9	20	-	-	Y
17	8.0	21	-	-	Y
18	8.0	20	-	-	Y
19	8.0	20	-	-	Y
20	8.0	21	-	-	Y
21	8.0	21	-	-	Y
22	8.0	21	-	-	Y
23	8.0	22	-	-	Y
24	8.0	22	-	-	Y
25	8.0	22	-	-	Y
26	8.0	22	-	-	Y
27	8.0	22	-	-	Y
28	7.8	22	-	-	Y
29	7.8	23	-	-	Y
30	7.8	24	-	-	Y
31	7.8	24	-	-	Y

Total N's 0

Notes:

<<Have minimums
 been met for
 this day?

County: Lane Agency: REGION 2

**ENTRY POINT
 EP-A**

**PWS ID 4100287
 EUGENE WATER & ELECTRIC BOARD**

Sample Period:

January 2021

 Month/Year

Number of excursions* during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

An "excursion" is any day in which the water quality parameter(s) fall below the minimum set by the State.

Is the system in compliance? Yes

Reference

**Minimum Water Quality
 Parameters as set by the State:**

pH 7.6

Print Name: _____

Signature: _____

Phone #: 541-685-7838

Date: Feb 2, 2021