



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
01	7.8	24	-	-	Y
02	7.8	25	-	-	Y
03	7.9	24	-	-	Y
04	7.9	25	-	-	Y
05	8.0	26	-	-	Y
06	8.0	27	-	-	Y
07	7.9	27	-	-	Y
08	7.9	27	-	-	Y
09	7.9	26	-	-	Y
10	8.0	27	-	-	Y
11	7.9	27	-	-	Y
12	8.0	27	-	-	Y
13	7.9	27	-	-	Y
14	7.9	27	-	-	Y
15	7.8	27	-	-	Y
16	8.0	26	-	-	Y
17	8.0	26	-	-	Y
18	7.9	27	-	-	Y
19	7.9	27	-	-	Y
20	8.0	27	-	-	Y
21	8.0	27	-	-	Y
22	8.0	28	-	-	Y
23	8.0	27	-	-	Y
24	8.0	28	-	-	Y
25	7.9	28	-	-	Y
26	7.9	28	-	-	Y
27	7.9	28	-	-	Y
28	8.0	27	-	-	Y
29	7.9	27	-	-	Y
30	7.9	28	-	-	Y
31	8.1	27	-	-	Y

Total N's 0

Notes:

<<Have minimums
been met for
this day?

County: Lane Agency: REGION 2

**ENTRY POINT
EP-A**

**PWS ID 4100287
EUGENE WATER & ELECTRIC BOARD**

Sample Period:

July 2021

Month/Year

Number of excursions* during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

An "excursion" is any day in which the water quality parameter(s) fall below the minimum set by the State.

Is the system in compliance? Yes

Reference

**Minimum Water Quality
Parameters as set by the State:**

pH 7.6

Print Name: _____

Signature: _____

Phone #: _____

541-685-7838

Date: _____

Aug 3, 2021