



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
01	7.9	22	-	-	Y
02	7.8	21	-	-	Y
03	7.9	22	-	-	Y
04	7.9	22	-	-	Y
05	7.9	22	-	-	Y
06	7.9	23	-	-	Y
07	8.0	23	-	-	Y
08	7.9	23	-	-	Y
09	7.9	23	-	-	Y
10	7.8	23	-	-	Y
11	7.8	24	-	-	Y
12	7.8	24	-	-	Y
13	7.9	24	-	-	Y
14	7.9	24	-	-	Y
15	7.9	24	-	-	Y
16	7.9	24	-	-	Y
17	7.9	24	-	-	Y
18	7.9	24	-	-	Y
19	7.9	24	-	-	Y
20	7.9	24	-	-	Y
21	7.9	24	-	-	Y
22	7.9	24	-	-	Y
23	7.9	23	-	-	Y
24	7.9	24	-	-	Y
25	7.9	24	-	-	Y
26	7.9	24	-	-	Y
27	7.9	23	-	-	Y
28	7.9	25	-	-	Y
29	7.9	24	-	-	Y
30	8.0	24	-	-	Y
31	8.0	24	-	-	Y

**Total N's** 0

**Notes:**

<<Have  
 minimums  
 been met for

County: Lane Agency: REGION 2

**ENTRY POINT  
 EP-A**

**PWS ID 4100287  
 EUGENE WATER & ELECTRIC BOARD**

**Sample Period:**

November 2022  
 Month/Year

**Number of excursions\* during this month: 0**

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)*

An "excursion" is any day in which the water quality parameter(s) fall below the minimum set by the State.

**Is the system in compliance? Yes**

Reference

**Minimum Water Quality  
 Parameters as set by the State:**

pH 7.6

**Print  
 Signature:  
 Phone #:  
 Date:**

\_\_\_\_\_  
 \_\_\_\_\_  
 (541) 685-7838  
 \_\_\_\_\_  
 Dec 6, 2022