



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
01	7.9	20	-	-	Y
02	7.9	20	-	-	Y
03	7.8	20	-	-	Y
04	7.9	21	-	-	Y
05	7.9	20	-	-	Y
06	7.9	20	-	-	Y
07	7.9	20	-	-	Y
08	7.9	20	-	-	Y
09	7.9	21	-	-	Y
10	7.9	21	-	-	Y
11	8.0	21	-	-	Y
12	7.9	21	-	-	Y
13	7.9	20	-	-	Y
14	8.0	20	-	-	Y
15	7.9	20	-	-	Y
16	7.9	20	-	-	Y
17	7.9	20	-	-	Y
18	7.9	20	-	-	Y
19	7.9	20	-	-	Y
20	7.9	19	-	-	Y
21	7.9	19	-	-	Y
22	7.9	20	-	-	Y
23	8.0	19	-	-	Y
24	7.9	20	-	-	Y
25	7.9	21	-	-	Y
26	7.8	21	-	-	Y
27	7.8	22	-	-	Y
28	7.8	22	-	-	Y
29	7.8	22	-	-	Y
30	7.9	22	-	-	Y
31	7.9	23	-	-	Y

**Total N's** 0

**Notes:**

<<Have  
 minimums  
 been met for

County: Lane Agency: REGION 2

**ENTRY POINT  
 EP-A**

**PWS ID 4100287  
 EUGENE WATER & ELECTRIC BOARD**

**Sample Period:**

May 2023  
 Month/Year

**Number of excursions\* during this month: 0**

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)*

An "excursion" is any day in which the water quality parameter(s) fall below the minimum set by the State.

**Is the system in compliance? Yes**

Reference

**Minimum Water Quality  
 Parameters as set by the State:**

pH 7.6

**Print  
 Signature:**

**Phone #:**

**Date:**

(541) 685-7838

Jun 6, 2023

Send to DHS within 10 days after end of sampling period

Department Human Services, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405

Website: <http://oregon.gov/DHS/ph/dwp/index.shtml>