



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
01	7.9	27	-	-	Y
02	7.9	27	-	-	Y
03	7.9	24	-	-	Y
04	7.8	21	-	-	Y
05	7.9	19	-	-	Y
06	7.9	20	-	-	Y
07	7.9	20	-	-	Y
08	8.0	20	-	-	Y
09	8.0	19	-	-	Y
10	8.0	19	-	-	Y
11	7.9	20	-	-	Y
12	7.9	19	-	-	Y
13	7.9	19	-	-	Y
14	7.9	19	-	-	Y
15	7.9	20	-	-	Y
16	7.9	20	-	-	Y
17	7.9	20	-	-	Y
18	7.9	20	-	-	Y
19	7.9	21	-	-	Y
20	7.9	21	-	-	Y
21	7.9	23	-	-	Y
22	7.9	24	-	-	Y
23	7.9	23	-	-	Y
24	8.0	23	-	-	Y
25	8.0	24	-	-	Y
26	8.0	25	-	-	Y
27	7.9	25	-	-	Y
28	7.9	25	-	-	Y
29	7.9	25	-	-	Y
30	7.9	24	-	-	Y
31	7.9	25	-	-	Y

Total N's 0

Notes:

<<Have minimums been met for	County: Lane Agency: REGION 2 <div style="text-align: center;"> ENTRY POINT EP-A PWS ID 4100287 EUGENE WATER & ELECTRIC BOARD </div>
Sample Period:	December 2023 <hr/> Month/Year

Number of excursions* during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

An "excursion" is any day in which the water quality parameter(s) fall below the minimum set by the State.

Is the system in compliance? Yes

Reference Minimum Water Quality Parameters as set by the State: pH 7.6

Print Signature:	
Phone #:	(541) 685-7838
Date:	Jan 4, 2024