



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
01	8.0	26	-	-	Y
02	8.0	26	-	-	Y
03	8.0	26	-	-	Y
04	8.0	26	-	-	Y
05	8.0	26	-	-	Y
06	8.0	26	-	-	Y
07	8.0	26	-	-	Y
08	7.9	26	-	-	Y
09	8.0	26	-	-	Y
10	7.9	25	-	-	Y
11	7.9	26	-	-	Y
12	7.9	26	-	-	Y
13	7.9	26	-	-	Y
14	7.9	26	-	-	Y
15	8.0	26	-	-	Y
16	8.0	25	-	-	Y
17	8.0	25	-	-	Y
18	8.0	26	-	-	Y
19	8.0	26	-	-	Y
20	8.0	26	-	-	Y
21	8.0	27	-	-	Y
22	8.0	27	-	-	Y
23	8.0	26	-	-	Y
24	8.0	25	-	-	Y
25	7.9	26	-	-	Y
26	8.0	27	-	-	Y
27	7.9	27	-	-	Y
28	7.9	26	-	-	Y
29	7.9	26	-	-	Y
30	7.9	26	-	-	Y
31	7.9	26	-	-	Y
Total N's					0

Notes:

<<Have
minimums
been met for

County: Lane

Agency: REGION 2

**ENTRY POINT
EP-A**

**PWS ID 4100287
EUGENE WATER & ELECTRIC BOARD**

Sample Period:

August 2025
Month/Year

Number of excursions* during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

An "excursion" is any day in which the water quality parameter(s) fall below the minimum set by the State.

Is the system in compliance? Yes

Reference

**Minimum Water Quality
Parameters as set by the State:**

pH 7.6

**Print
Signature:
Phone #:
Date:**

(541) 685-7836

Sep 2, 2025