Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

ID #	Sample Location	pH	Alk	PO4	other	Y/N
	3360 Buckingham Ave	8.0	24			Y
	2835 Applewood Ln	8.0	24			Y
	306 Lynnbrook Dr	8.0	23			Y
	833 Virgil Ave	8.1	24			Y
	4165 Avalon St	8.2	25			Y
	2896 Timberline Dr	7.9	23			Y
	863 W 38th Ave	8.3	24			Y
	5141 Solar Heights Dr	8.1	23			Y
	1724 Lawrence St	7.9	23			Y
	2178 Kimberly Circle	8.0	24			Y

(N = No = Excursion) **Total N's** 0

<Has sample met the minimums?

DISTRIBUTION

PWS ID: 41 0 0 2 8 7

System Name: Eugene Water & Electric Board

Sample Period: 06/2021
Month/Year

Sample Frequency: 36 Months

Distribution Samples required: 10

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.4

Alk N/A *(Alkalinity)*

PO4 *(Orthophosphate)*

Other *(_____)*

Print Name: _____

Signature: Ray Leipold Digitally signed by Ray Leipold Date: 2021.07.06 12:15:54 -07'00'

Date: _____

Send to Drinking Water Program within 10 days after end of sampling period:

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: http://healthoregon.org/dwp/