

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.81				
4					
5	8.1				
6					
7					
8	8.8				
9					
10					
11					
12					
13	7.54				
14					
15					
16					
17					
18					
19	7.5				
20					
21					
22					
23					
24	7.48				
25					
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Big Spruce MHP

Entry Point: EP-A

Sample Period: March / 2022
 Month/Year

Number of excursions* during this month: _____
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other

Print Name: Kathy JOHNSON

Signature: [Signature]

Date: 04/01/2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's