

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.6				
4					
5					
6					
7	7.41				
8					
9					
10	7.8				
11					
12					
13					
14					
15					
16					
17					
18	7.49				
19					
20					
21					
22					
23					
24	7.4				
25					
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Big Spruce MHP

Entry Point: EP-A

Sample Period: JUNE 2022
Month/Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: KARLY JOHNSON

Signature: [Signature]

Date: 07/05/2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's