

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.2				
3	7.4				
4					
5					
6	7.3				
7					
8	7.3				
9	7.3				
10					
11					
12					
13					
14	7.1				
15	7.4				
16	7.4				
17	7.4				
18					
19					
20	7.4				
21	7.1				
22	7.2				
23					
24					
25					
26	7.2				
27					
28					
29					
30	7.3				
31					

(No = N = Excursion) Total N's

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 00295

System Name: Big Spruce MHC

Entry Point: OSSICA

Sample Period: Jan. 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 71
Alk (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: Patrick Crouch

Signature: [Signature]

Date: 01-31-2025

Send to DWP within 10 days after end of
sampling period