

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.4				Y
4					
5					
6					
7	7.2				Y
8					
9	7.4				Y
10					
11	7.6				Y
12					
13					
14	7.4				Y
15					
16					
17	7.6				Y
18					
19					
20					
21	7.4				Y
22					
23					
24					
25	7.4				Y
26					
27					
28	7.4				Y
29					
30					
31					

(No = N = Excursion) Total N's

0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 00295

System Name: Big Spruce MHC

Entry Point: Office

Sample Period: Feb. 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH 7.1
Alk (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: Patrick Crouch
Signature: [Signature]
Date: Feb 28 - 2025

Send to DWP within 10 days after end of
sampling period