

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.32				Y
2					Y
3					
4	7.1				Y
5	7.1				Y
6					Y
7					
8	7.2				Y
9					Y
10					
11	7.1				Y
12					Y
13	7.3				Y
14					Y
15					
16	7.2				Y
17					Y
18					
19	7.1				Y
20					Y
21					
22	7.1				Y
23					Y
24	7.1				Y
25					Y
26					
27	7.2				Y
28					Y
29					
30	7.4				Y
31					Y

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 00295

System Name: Big Spruce MHC

Entry Point: Pump House

Sample Period: 06/2025
Month/Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH 7.1
Alk (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: Jenna Shaughnessy

Signature: [Signature]

Date: 07/17/25

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0