

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.4				Y
2					
3					
4	7.2				Y
5					
6					
7					
8	7.2				Y
9					
10					
11	7.1				Y
12					
13					
14	7.3				Y
15					
16					
17	7.1				Y
18					
19	7.3				Y
20					
21					
22	7.3				Y
23					
24					
25	7.2				Y
26					
27	7.3				Y
28					
29					
30	7.3				Y
31					

(No = N = Excursion) Total N's 0

<<Have

minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 00295

System Name: Big Spruce mtc

Entry Point: PH 4 OFF

Sample Period: July 2025
Month/Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.1
Alk (Alkalinity)
PO4 (Orthophosphate)
Other

Print Name: Jonna Shaughnessy

Signature: [Signature]

Date: 8/4/23

Send to DWP within 10 days after end of sampling period