

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.18				N
2	7.3				N
3					
4					
5	7.4				N
6					
7					
8					
9	7.2				N
10					
11					
12					
13	7.5				N
14					
15					
16					
17	7.1				N
18					
19	7.1				N
20					
21	7.4				N
22					
23					
24					
25	7.2				N
26					
27					
28	7.17				N
29					
30					
31	7.5				N

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00295

System Name: Big Spruce

Entry Point: Office/House

Sample Period: October 2025
Month/Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.1
Alk (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: Joanna Shayhnessy

Signature: [Signature]

Date: 11/3/25

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's