

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4	7.2				
5					
6					
7	7.13				
8	7.11				
9					
10					
11					
12	7.39				
13					
14					
15	7.39				
16					
17					
18					
19	7.28				
20					
21					
22	7.10				
23					
24					
25					
26					
27	7.37				
28					
29					
30	7.2				
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00295

System Name: Big Spruce

Entry Point: Office/House

Sample Period: January 2026
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.1
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other ()

Print Name: Jonna Shayhnessy

Signature: [Signature]

Date: 02/03/26

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0