



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

ID #	Sample Location	pH	Alk	PO4	other	Y/N
3/1	office	6.9				N
3/3	pump house	7.2				Y
3/5	office	7.3				Y
3/5	pump house	7.35				Y
3/6	# 37	7.2				Y
3/6	pump house	7.3				Y
3/8	office	7.2				Y
3/10	pumphouse	7.1				Y
3/12	# 37	7.3				Y
3/12	office	7.2				Y
3/14	pump house	7.0				Y
3/16	# 37	7.23				Y
3/18	office	7.0				Y
3/20	office	7.3				Y
3/22	# 37	7.25				Y
3/23	pumphouse	7.3				Y
3/25	# 37	7.8				Y
3/26	# 37	7.3				Y
3/28	office	7.3				Y
3/29	# 37	7.1				Y
3/31	pump house	6.9				N

<Has sample met the minimums? **DISTRIBUTION**

PWS ID: 41

System Name: Big Spruce MHP

Sample Period: March 2024  
Month/Year

Sample Frequency: 3 years/ w L&C Samples

Distribution Samples required: 1

Number of excursions during this Sample Period = 2

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

For OHA use only

**Minimum Water Quality Parameters as set by**

pH

Alk  (Alkalinity)

PO4  (Orthophosphate)

Other  ( )

Print Name: Asnley McAnley

Signature: [Signature]

Date: 4/8/2024

(N = No = Excursion) Total N's 2

Send to Drinking Water Program within 10 days after end of sampling period:  
 OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>