



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.3				Y
2	7.3				Y
3	7.2				Y
4	7.3				Y
5	7.3				Y
6	7.3				Y
7	7.3				Y
8	7.3				Y
9	7.3				Y
10	7.3				Y
11	7.3				Y
12	7.3				Y
13	7.3				Y
14	7.3				Y
15	7.3				Y
16	7.3				Y
17	7.3				Y
18	7.3				Y
19	7.3				Y
20	7.3				Y
21	7.3				Y
22	7.3				Y
23	7.3				Y
24	7.4				Y
25	7.3				Y
26	7.3				Y
27	7.3				Y
28	7.3				Y
29					
30					
31					
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

Entry Point

PWS ID: 41 0 0 3 0 1

System Name: Heceta Water P.U.D.

Entry Point: Treatment Plant

Sample Period: February 2021
Month/Year

Number of excursions* during this month: 6
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Carl Neville

Signature:

Date: 3-3-21

Send to DHS within 10 days after end of sampling period

DHS - Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381