



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.3				Y
2	7.3				Y
3	7.3				Y
4	7.3				Y
5	7.3				Y
6	7.3				Y
7	7.4				Y
8	7.3				Y
9	7.3				Y
10	7.3				Y
11	7.3				Y
12	7.3				Y
13	7.3				Y
14	7.3				Y
15	7.4				Y
16	7.3				Y
17	7.3				Y
18	7.3				Y
19	7.3				Y
20	7.3				Y
21	7.3				Y
22	7.3				Y
23	7.3				Y
24	7.3				Y
25	7.2				Y
26	7.2				Y
27	7.2				Y
28	7.2				Y
29	7.1				Y
30	7.3				Y
31	7.3				Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

Entry Point

PWS ID: 41

0	0	3	0	1
---	---	---	---	---

System Name: Heceta Water P.U.D.

Entry Point: Treatment Plant

Sample Period: August 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	<table border="1" style="width: 100%; height: 20px;"><tr><td style="text-align: center;">7.0</td></tr></table>	7.0	
7.0			
Alk	<table border="1" style="width: 100%; height: 20px;"><tr><td style="text-align: center;">7.0</td></tr></table>	7.0	(Alkalinity)
7.0			
PO4	<table border="1" style="width: 100%; height: 20px;"><tr><td style="text-align: center;">7.0</td></tr></table>	7.0	(Orthophosphate)
7.0			
Sili	<table border="1" style="width: 100%; height: 20px;"><tr><td style="text-align: center;">7.0</td></tr></table>	7.0	(Silicate)
7.0			

Print Name: Carl Neville

Signature:

Date: 8.2.21

Send to DHS within 10 days after end of sampling period

DHS - Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381