



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.3				Y
2	7.3				Y
3	7.3				Y
4	7.3				Y
5	7.3				Y
6	7.3				Y
7	7.2				Y
8	7.3				Y
9	7.3				Y
10	7.3				Y
11	7.3				y
12	7.3				y
13	7.3				Y
14	7.3				Y
15	7.3				Y
16	7.3				Y
17	7.3				Y
18	7.3				Y
19	7.3				Y
20	7.2				Y
21	7.2				Y
22	7.3				Y
23	7.3				Y
24	7.3				Y
25	7.2				Y
26	7.2				Y
27	7.2				Y
28	7.2				Y
29	7.2				Y
30	7.3				Y
31	7.3				Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

### Entry Point

**PWS ID: 41** 0 0 3 0 1

**System Name:** Heceta Water P.U.D.

**Entry Point:** Treatment Plant

**Sample Period:** August 2022  
Month/Year

**Number of excursions\* during this month:** 0  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

### Minimum Water Quality Parameters as set by State:

pH	7.0	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

**Print Name:** Carl Neville

**Signature:** *Carl Neville*

**Date:** 9/2/22