



## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.4	15.1			Y
2	7.4	15			Y
3	7.3	14.1			Y
4	7.3	15.6			Y
5	7.3	14.3			Y
6	7.3	16.1			Y
7	7.3	16.5			Y
8	7.3	17.1			Y
9	7.3	15.1			Y
10	7.3	14.9			Y
11	7.3	15.2			Y
12	7.3	15.6			Y
13	7.3	15.9			Y
14	7.3	15.4			Y
15	7.3	15.3			Y
16	7.3	15.1			Y
17	7.3	15.5			Y
18	7.3	16.3			Y
19	7.3	16.1			Y
20	7.3	15.3			Y
21	7.2	15.7			Y
22	7.3	15.6			Y
23	7.3	15.9			Y
24	7.3	15.7			Y
25	7.3	15.9			Y
26	7.3	15			Y
27	7.3	15.2			Y
28	7.3	14.5			Y
29	7.3	15.2			Y
30	7.2	16.5			Y
31	7.2	15.6			Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

### Entry Point

**PWS ID: 41**

0	0	3	0	1
---	---	---	---	---

**System Name:** Heceta Water P.U.D.

**Entry Point:** Treatment Plant

**Sample Period:** July 2023  
Month/Year

**Number of excursions\* during this month:** 0  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

### Minimum Water Quality Parameters as set by State:

pH		
Alk		(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

**Print Name:** Carl Neville

**Signature:**

**Date:** 8.4.2023