



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.1	17.8			Y
2	7.2	18.3			Y
3	7.1	17.9			Y
4	7.1	18.7			Y
5	7.2	17.7			Y
6	7.3	17.7			Y
7	7.3	17.7			Y
8	7.3	17.9			Y
9	7.3	17.9			Y
10	7.4	18.3			Y
11	7.3	18.1			Y
12	7.3	18.3			Y
13	7.4	18.3			Y
14	7.4	18.3			Y
15	7.3	17.5			Y
16	7.2	17.4			Y
17	7.2	16.7			Y
18	7.3	18.1			Y
19	7.3	17.5			Y
20	7.2	17.3			Y
21	7.1	17.7			Y
22	7.2	18.8			Y
23	7.2	19.2			Y
24	7.2	19.4			Y
25	7.2	19.1			Y
26	7.2	18.7			Y
27	7.3	18.5			Y
28	7.1	18.5			Y
29	7.2	18.2			Y
30	7.2	17			Y
31	7.1	17.6			Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

Entry Point

PWS ID: 41 0 0 3 0 1

System Name: Heceta Water P.U.D.

Entry Point: Treatment Plant

Sample Period: December 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	<input type="checkbox"/>	
Alk	<input checked="" type="checkbox"/>	(Alkalinity)
PO4	<input type="checkbox"/>	(Orthophosphate)
Sili	<input type="checkbox"/>	(Silicate)

Print Name: Carl Neville

Signature: *Carl Neville*

Date: 1.2.24

Send to DHS within 10 days after end of sampling period

DHS - Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381