



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.3	15.7			Y
2	7.3	15.5			Y
3	7.3	16.6			Y
4	7.2	16.8			Y
5	7.2	16.5			Y
6	7.3	16.7			Y
7	7.3	16.7			Y
8	7.3	16.7			Y
9	7.3	15.5			Y
10	7.3	16.6			Y
11	7.3	16.2			Y
12	7.3	16.8			Y
13	7.3	16.1			Y
14	7.3	16.3			Y
15	7.3	15.8			Y
16	7.3	16.5			Y
17	7.4	16.4			Y
18	7.3	17			Y
19	7.3	16.8			Y
20	7.3	16			Y
21	7.3	17			Y
22	7.3	16.1			Y
23	7.4	16.5			Y
24	7.4	16.7			Y
25	7.4	16.7			Y
26	7.4	15.8			Y
27	7.4	15.3			Y
28	7.4	15.3			Y
29	7.3	15			Y
30	7.4	15.7			Y
31					
(No = N = Excursion) Total N's					0

<<Have
minimums
been met
for this day?

Entry Point

PWS ID: 41

System Name: Heceta Water P.U.D.

Entry Point: Treatment Plant

Sample Period: September 2024
Month/Year

Number of excursions* during this month: _____

(Count the number of days when any WQP was less
than the minimum required)

Total excursions during the previous 5 months: _____

(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.2	
Alk	15.0	(Alkalinity)
PO4	0.1	(Orthophosphate)
Sili	0.1	(Silicate)

Print Name: Carl Neville

Signature:

Date: 10.2.24

Send to DHS within 10 days after end of sampling period

DHS - Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381