



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.2	17			Y
2	7.2	17.2			Y
3	7.1	17.9			Y
4	7.2	18.7			Y
5	7.2	19.1			Y
6	7.1	18			Y
7	7.1	18.6			Y
8	7.1	18.8			Y
9	7.1	18.8			Y
10	7.1	17.9			Y
11	7.2	17.3			Y
12	7.1	17.5			Y
13	7.1	18.7			Y
14	7.1	18.2			Y
15	7.2	18			Y
16	7.2	17.9			Y
17	7.2	18.2			Y
18	7.3	18.3			Y
19	7.3	18.3			Y
20	7.3	19.1			Y
21	7.3	18.5			Y
22	7.3	17.4			Y
23	7.3	19			Y
24	7.3	18.4			Y
25	7.3	17.8			Y
26	7.3	17.2			Y
27	7.4	18.9			Y
28	7.4	17.9			Y
29	7.4	18.1			Y
30	7.4	18.3			Y
31	7.4	17.7			Y
(No = N = Excursion) Total N's					0

<<Have
minimums
been met
for this day?

Entry Point

PWS ID: 41

System Name: Heceta Water P.U.D.

Entry Point: Treatment Plant

Sample Period: December 2024
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.0	
Alk	17.0	(Alkalinity)
PO4	0.1	(Orthophosphate)
Sili	0.1	(Silicate)

Print Name: Carl Neville

Signature: _____

Date: 1-2-2025

Send to DHS within 10 days after end of sampling period

DHS - Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381