



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.3	14.8			Y
2	7.3	15.2			Y
3	7.4	15.2			Y
4	7.3	14.9			Y
5	7.3	14.8			Y
6	7.3	15.1			Y
7	7.4	14.7			Y
8	7.3	14.6			Y
9	7.3	15.9			Y
10	7.3	15.7			Y
11	7.3	15.7			Y
12	7.3	15.1			Y
13	7.4	15.9			Y
14	7.4	15.1			Y
15	7.3	15.5			Y
16	7.3	15.4			Y
17	7.2	15.6			Y
18	7.2	15.2			Y
19	7.2	14.9			Y
20	7.2	15			Y
21	7.2	14.7			Y
22	7.2	14.7			Y
23	7.2	15			Y
24	7.2	14.7			Y
25	7.2	15.4			Y
26	7.3	15.3			Y
27	7.3	15.6			Y
28	7.3	15.8			Y
29	7.3	15.8			Y
30	7.2	15.9			Y
31					
(No = N = Excursion) Total N's					0

<<Have
minimums
been met
for this day?

Entry Point

PWS ID: 41 0 0 3 0 1

System Name: Heceta Water P.U.D.

Entry Point: Treatment Plant

Sample Period: June 2025
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH
Alk (Alkalinity)
PO4 (Orthophosphate)
Sili (Silicate)

Print Name: Carl Neville

Signature: _____

Date: 7-2-2025

Send to DHS within 10 days after end of sampling period

DHS - Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381