



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.4	14.1			Y
2	7.4	14.6			Y
3	7.4	14.8			Y
4	7.4	15.1			Y
5	7.4	15.8			Y
6	7.3	16.6			Y
7	7.3	15.5			Y
8	7.3	16.2			Y
9	7.3	15.9			Y
10	7.3	15.7			Y
11	7.3	15.4			Y
12	7.3	15.5			Y
13	7.3	15			Y
14	7.3	15.1			Y
15	7.3	14.8			Y
16	7.3	14.2			Y
17	7.3	14.9			Y
18	7.3	15			Y
19	7.3	15.3			Y
20	7.3	14.2			Y
21	7.3	14			Y
22	7.3	13.5			Y
23	7.3	14.2			Y
24	7.2	14.2			Y
25	7.2	14			Y
26	7.2	14.2			Y
27	7.1	16.5			Y
28	7.2	15.9			Y
29	7.1	16			Y
30	7.1	14.5			Y
31	7.1	14.7			Y
(No = N = Excursion) Total N's					0

<<Have
minimums
been met
for this day?

Entry Point

PWS ID: 41

0	0	3	0	1
---	---	---	---	---

System Name: Heceta Water P.U.D.

Entry Point: Treatment Plant

Sample Period: October 2025
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH		
Alk		(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Carl Neville

Signature: Carl Neville Digitally signed by Carl Neville
Date: 2025.11.03 15:07:19
+08'00'

Date: 11-3-2025

Send to DHS within 10 days after end of sampling period

DHS - Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381