



## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.3	17.2			Y
2	7.2	19.2			Y
3	7.3	17.7			Y
4	7.3	18.9			Y
5	7.3	17			Y
6	7.3	19.7			Y
7	7.3	18.6			Y
8	7.3	19.1			Y
9	7.3	19.1			Y
10	7.4	18.3			Y
11	7.3	18.3			Y
12	7.4	18.9			Y
13	7.3	18.5			Y
14	7.2	18.7			Y
15	7.3	18.9			Y
16	7.4	18			Y
17	7.3	17.6			Y
18	7.3	16.1			Y
19	7.4	17.4			Y
20	7.3	17.1			Y
21	7.3	17.2			Y
22	7.3	16.4			Y
23	7.3	19.2			Y
24	7.4	18.6			Y
25	7.4	18.2			Y
26	7.5	18.7			Y
27	7.4	17.6			Y
28	7.4	17.7			Y
29					
30					
31					
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

**Entry Point**

PWS ID: 41 0 0 3 0 1

**System Name:** Heceta Water P.U.D.

**Entry Point:** Treatment Plant

**Sample Period:** February 2026  
Month/Year

**Number of excursions\* during this month:** 0  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by State:**

pH	☑	
Alk	☑	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

**Print Name:** Carl Neville

**Signature:** \_\_\_\_\_

**Date:** 3-3-2026