

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.4				Y
2	7.4				Y
3	7.4				Y
4	7.4				Y
5	7.3				Y
6	7.4				Y
7	7.3				Y
8	7.3				Y
9	7.3				Y
10	7.5				Y
11	7.9				Y
12	8.1				Y
13	8.7				Y
14	8.4				Y
15	8.2				Y
16	8.3				Y
17	8.4				Y
18	9.1				Y
19	8.9				Y
20	9.0				Y
21	8.6				Y
22	8.0				Y
23	7.8				Y
24	7.7				Y
25	7.6				Y
26	7.5				Y
27	7.4				Y
28	7.4				Y
29	7.3				Y
30	7.3				Y
31	7.3				Y

(No = N = Excursion) **Total N's** 0

<<Have

minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 00302

System Name: SOUTH COAST WATER DIST.

Entry Point: EP-A

Sample Period: MARCH 2021

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by


pH 7.2

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: DAN REITZ

Signature: 

Date: 04/05/2021

Send to DWP within 10 days after end of sampling period