

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.6				Y
2	7.6				Y
3	7.6				Y
4	7.6				Y
5	7.6				Y
6	7.6				Y
7	7.5				Y
8	7.5				Y
9	7.6				Y
10	7.6				Y
11	7.7				Y
12	7.7				Y
13	7.7				Y
14	7.4				Y
15	7.8				Y
16	7.8				Y
17	7.8				Y
18	7.8				Y
19	7.8				Y
20	7.8				Y
21	7.8				Y
22	7.8				Y
23	7.8				Y
24	7.8				Y
25	7.7				Y
26	7.7				Y
27	7.6				Y
28	7.8				Y
29	7.8				Y
30	7.8				Y
31					Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: SOUTH COAST WATER DIST.

Entry Point: EP-A

Sample Period: April 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: DAN REITZ

Signature:

Date: 5/1/2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**