

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.7				Y
2	7.5				Y
3	7.2				Y
4	7.8				Y
5	7.2				Y
6	7.5				Y
7	7.4				Y
8	7.3				Y
9	7.3				Y
10	7.2				Y
11	7.3				Y
12	7.3				Y
13	7.4				Y
14	7.5				Y
15	7.4				Y
16	7.3				Y
17	7.2				Y
18	7.2				Y
19	7.2				Y
20	7.4				Y
21	7.6				Y
22	7.5				Y
23	7.3				Y
24	7.4				Y
25	7.4				Y
26	7.2				Y
27	7.5				Y
28	7.2				Y
29	7.5				Y
30	7.2				Y
31	7.3				Y

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day?

## ENTRY POINT

**PWS ID:** 41 00302

**System Name:** SOUTH COAST WATER DIST.

**Entry Point:** EP-A

**Sample Period:** May 2024  
*Month/Year*

**Number of excursions\* during this month:** 0  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:** 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )*

*For OHA use only*

### Minimum Water Quality Parameters as set by

pH 7.2

Alk    *(Alkalinity)*

PO4    *(Orthophosphate)*

Other    *(\_\_\_\_\_)*

**Print Name:** DAN REITZ

**Signature:**

**Date:** 6/03/24

Send to DWP within 10 days after end of sampling period