

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.5				Y
2	7.5				Y
3	7.5				Y
4	7.5				Y
5	7.5				Y
6	7.5				Y
7	7.5				Y
8	7.5				Y
9	7.5				Y
10	7.5				Y
11	7.5				Y
12	7.5				Y
13	7.5				Y
14	7.5				Y
15	7.5				Y
16	7.5				Y
17	7.6				Y
18	7.6				Y
19	7.6				Y
20	7.6				Y
21	7.8				Y
22	7.5				Y
23	7.6				Y
24	7.6				Y
25	7.7				Y
26	7.7				Y
27	7.6				Y
28	7.6				Y
29					
30					
31					

(No = N = Excursion) **Total N's** 0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 00302

System Name: SOUTH COAST WATER DIST.

Entry Point: EP-A

Sample Period: February 2025

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: DAN REITZ

Signature: 

Date: 03/10/2025

Send to DWP within 10 days after end of sampling period