

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.2				Y
2	7.2				Y
3	7.2				Y
4	7.2				Y
5	7.2				Y
6	7.3				Y
7	7.2				Y
8	7.2				Y
9	7.3				Y
10	7.5				Y
11	7.4				Y
12	7.4				Y
13	7.4				Y
14	7.5				Y
15	7.4				Y
16	7.3				Y
17	7.3				Y
18	7.3				Y
19	7.3				Y
20	7.3				Y
21	7.3				Y
22	7.3				Y
23	7.4				Y
24	7.3				Y
25	7.4				Y
26	7.4				Y
27	7.4				Y
28	7.4				Y
2	7.4				Y
3	7.4				Y
3	7.4				Y
(No = N = Excursion) Total N's					0

<<Have

minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 00302

System Name: SOUTH COAST WATER DIST.

Entry Point: EP-

Sample Period: MAY 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)


Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other (_____)

Print Name: DAN

Signature: 

Date: 06/02/2025

Send to DWP within 10 days after end of sampling period