

# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.4				Y
2	7.4				Y
3	7.4				Y
4	7.4				Y
5	7.4				Y
6	7.4				Y
7	7.4				Y
8	7.4				Y
9	7.4				Y
10	7.5				Y
11	7.5				Y
12	7.5				Y
13	7.5				Y
14	7.5				Y
15	7.4				Y
16	7.4				Y
17	7.4				Y
18	7.5				Y
19	7.4				Y
20	7.4				Y
21	7.4				Y
22	7.4				Y
23	7.4				Y
24	7.4				Y
25	7.4				Y
26	7.4				Y
27	7.4				Y
28	7.4				Y
29	7.3				Y
30	7.3				Y
31	7.4				Y
(No = N = Excursion) <b>Total N's</b>					0

<<Have

minimums  
been met for  
this day?

### ENTRY POINT

**PWS ID: 41**    0 0 3 0 2

**System Name:** SOUTH COAST WATER DIST.

**Entry Point:** EP-A

**Sample Period:** OCTOBER 2025  
Month/Year

**Number of excursions\* during this month:** 0  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

*For OHA use only*

#### Minimum Water Quality Parameters as set by

pH	<div style="border: 1px solid black; padding: 2px;">7.2</div>	
Alk	<div style="border: 1px solid black; padding: 2px;"></div>	(Alkalinity)
PO4	<div style="border: 1px solid black; padding: 2px;"></div>	(Orthophosphate)
Other	<div style="border: 1px solid black; padding: 2px;"></div>	(_____)

**Print Name:** DAN

**Signature:** 

**Date:** 11/07/2025

Send to DWP within 10 days after end of sampling period