

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	7.4				Y
6					
7					
8					
9					
10					
11					
12	7.55				Y
13					
14					
15					
16					
17	7.61				Y
18					
19					
20					
21					
22	7.44				Y
23					
24					
25					
26	7.82				Y
27					
28					
29					
30	7.62				Y
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: City of Garibaldi

Entry Point: First hydrant before services

Sample Period: August / 2022
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other

Print Name: Kelly West

Signature: [Signature]

Date: 9-6-2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's