

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.2				Y
4					
5					
6					
7					
8					
9					
10					
11					
12					
13	7.19				Y
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24	7.1				Y
25					
26					
27	7.1				Y
28					
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: City of Garibaldi

Entry Point: First hydrant before services

Sample Period: February 2023
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: Kelly West

Signature: [Signature]

Date: 3-1-2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's