

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	7.2				Y
6					
7					
8					
9	7.2				Y
10					
11					
12	7.2				Y
13					
14					
15					
16					
17					
18					
19					
20	7.2				Y
21					
22					
23					
24					
25					
26	7.2				Y
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: City of Garibaldi

Entry Point: First hydrant before services

Sample Period: JUN/2023
 Month/Year

Number of excursions* during this month: _____
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.1"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Other	<input type="text"/>	(_____)

Print Name: EVERETTON J. GIVENS

Signature: [Signature]

Date: 07/05/2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's