

## Water Quality Parameter Monitoring Form

## **Lead & Copper Rule Corrosion Control**

Day	рН	Alk	Phos	Other	Y/N	< <have< th=""></have<>
1						minimums ENTRY POINT
2						been met for this day? PWS ID: 41 0 0 3 1 1
3	7.2				Y	and day.
4						System Name: City of Garibaldi
5						Entry Point: First hydrant before services
6						Sample Period: JULY /2023
7						Month/Year
8						Number of excursions* during this month:
9						(Count the number of days when any WQP was
10						less than the minimum required)
11	7.1			,	Y	
12						Total excursions during the previous 5 months:
13						(Over 9 excursions in 6 months is a violation. Entry
14						Point and Distribution excursions are cumulative )
15						For OHA use only
16 17						
18						Minimum Water Quality
	20				\/	Parameters as set by
20	7.9				7	pH 7.1
21						Alk (Alkalinity)
22						PO4 (Orthophosphate)
23						Other ()
24	8.5				У	
25						
26						
27						Print Name: Even by Miveira
28						
29						Signature:
30						
31	8.4				Y	Send to DWP within 10 days after end of sampling period
0 = N	= Exc	ursion	) Total	N's	0	adulbiing bound

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/