

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4	7.3				Y
5					
6					
7					
8					
9					
10					
11	7.3				Y
12					
13	7.2				Y
14					
15	7.4				Y
16					
17					
18					
19					
20					
21					
22	7.2				Y
23					
24					
25					
26	7.4				Y
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: City of Garibaldi

Entry Point: First hydrant before services

Sample Period: MARCH/2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.1"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Other	<input type="text"/>	()

Print Name: _____

Signature: Everton Oliveira

Date: 04/08/2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's