

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	рΗ	Alk	Phos	Other	Y/N	<-Have ENTRY DOINT	
1						minimums ENTRY POINT	
2						been met for this day? <b>PWS ID: 41</b> 0 0 3 1 1	
3						System Name: <u>City of Garibaldi</u>	
4							
5						Entry Point: First hydrant before services	
6	7.2				Y	Sample Period: December/ 2024	
7						Month/Year	
8						Number of excursions* during this month:_0	
9	7.8				Υ	(Count the number of days when any WQP was	
10						less than the minimum required)	
11							
12						Total excursions during the previous 5 months:	
13	7.5				Y	(Over 9 excursions in 6 months is a violation. Entry	
14						Point and Distribution excursions are cumulative )	
15						For OHA use only	
16	7.7				Y		
17						Minimum Water Quality	
18						Parameters as set by	
19						nH 7.1	
20	7.3				Y		
21						Alk <i>(Alkalinity)</i>	
22						PO4 (Orthophosphate)	
23						Other ()	
24							
25							
26							
27	8.4				Υ	Print Name: Nicholas Theoharis	
28						Signature: Nick Theoharis	
29						Date: 1/9/2025	
30	7.7				Y		
31						Send to DWP within 10 days after end of sampling period	
(No = N	No = N = Excursion) Total N's $0$						

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/