

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6	7.2				Y
7					
8					
9	7.8				Y
10					
11					
12					
13	7.5				Y
14					
15					
16	7.7				Y
17					
18					
19					
20	7.3				Y
21					
22					
23	7.8				Y
24					
25					
26					
27	8.4				Y
28					
29					
30	7.7				Y
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: City of Garibaldi

Entry Point: First hydrant before services

Sample Period: January/ 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other (_____)

Print Name: Nicholas Theoharis

Signature: *Nick Theoharis*

Date: 2/4/2025

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's