

Day	pH	Alk	Phos	Other	Y/N
1	7.38				Y
2	7.39				Y
3					
4					
5					
6					
7					
8	7.36				Y
9	7.29				Y
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23	7.26				Y
24	7.29				Y
25					
26					
27					
28					
29					
30	7.31				Y
31	7.33				Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: City of Garibaldi

Entry Point: First hydrant before services

Sample Period: March / 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.1"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Other	<input type="text"/>	()

Print Name: Nelly West
Signature: [Signature]
Date: 4-1-22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's