

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4	7.7				Y
5					
6					
7					
8					
9					
10					
11	7.6				Y
12					
13					
14					
15	7.12				Y
16					
17					
18	7.8				Y
19					
20					
21					
22					
23					
24					
25	7.5				Y
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: City of Garibaldi

Entry Point: First hydrant before services

Sample Period: April / 20 22
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by


pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: Kelley West

Signature: 

Date: 5-2-22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's