



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	OFF				OFF
2	7.70				Y
3	OFF				OFF
4	7.63				Y
5	OFF				OFF
6	OFF				OFF
7	7.67				Y
8	OFF				OFF
9	OFF				OFF
10	7.81	2.1			Y
11	OFF				OFF
12	OFF				OFF
13	7.59				Y
14	OFF				OFF
15	OFF				OFF
16	7.71				Y
17	OFF				OFF
18	OFF				OFF
19	7.75				Y
20	OFF				OFF
21	OFF				OFF
22	OFF				OFF
23	7.70				Y
24	OFF				OFF
25	OFF				OFF
26	7.69				Y
27	OFF				OFF
28	OFF	2.2			OFF
29	7.71				Y
30	OFF				Y
31	OFF				Y

County: Marion Agency: Region 1
ENTRY POINT
 <<Have minimums been met for this day? PWS ID: 41 0 0 3 1 7
 System Name: GATES, CITY OF
 Entry Point: EP-A
 Sample Period: January/2021
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by

pH	7.3	
Alk	19	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: GREGORY R BENTHIN
 Signature: *Gregory R Benthin*
 Date: 2-1-21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0